

Map ID
Direction
Distance
Elevation

MAP FINDINGS

Site

Database(s)

EDR ID Number
EPA ID Number

698
NW
1/2-1
0.997 mi.
5263 ft.

26 AVE. AND SHORE P'KWAY
26TH AVE. & SHORE P'KWAY
NEW YORK CITY, NY

NY LTANKS S100167430
N/A

Relative:
Higher

Actual:
20 ft.

LTANKS:

Name: 26 AVE. AND SHORE P'KWAY
Address: 26TH AVE. & SHORE P'KWAY
City,State,Zip: NEW YORK CITY, NY
Spill Number/Closed Date: 8704885 / 1993-11-17
Facility ID: 8704885
Site ID: 199440
Spill Date: 1987-09-11
Spill Cause: Tank Test Failure
Spill Source: Institutional, Educational, Gov., Other
Spill Class: A3
Cleanup Ceased: 1993-11-17
SWIS: 2401
Investigator: BATTISTA
Referred To: Not reported
Reported to Dept: 1987-09-11
CID: Not reported
Water Affected: Not reported
Spill Notifier: Tank Tester
Last Inspection: Not reported
Recommended Penalty: False
Meets Standard: True
UST Involvement: True
Remediation Phase: 0
Date Entered In Computer: 1987-09-16
Spill Record Last Update: 1994-05-26
Spiller Name: Not reported
Spiller Company: N.Y. TELEPHONE
Spiller Address: Not reported
Spiller County: 001

Spiller Contact: Not reported
Spiller Phone: Not reported
Spiller Extention: Not reported
DEC Region: 2
DER Facility ID: 165999
DEC Memo: ""
Remarks: "(2) 2000 GALLON TANKS- SYSTEM FAILED PETRO-TITE TEST-LEAK RATE
-0.560GPH."

All TTF:

Facility ID: 8704885
Spill Number: 8704885
Spill Tank Test: 1531608
Site ID: 199440
Tank Number: Not reported
Tank Size: 0
Material: 0009
EPA UST: Not reported
UST: Not reported
Cause: Not reported
Source: Not reported
Test Method: 00
Test Method 2: Unknown
Leak Rate: .00

Map ID
Direction
Distance
Elevation

MAP FINDINGS

Site

Database(s)

EDR ID Number
EPA ID Number

Gross Fail: Not reported
Modified By: Spills
Last Modified Date: Not reported

All Materials:

Site ID: 199440
Operable Unit ID: 908588
Operable Unit: 01
Material ID: 467499
Material Code: 0009
Material Name: gasoline
Case No.: Not reported
Material FA: Petroleum
Quantity: -1.00
Units: Not reported
Recovered: .00
Oxygenate: Not reported